

VILLAGE OF ORANGEVILLE

ORDINANCE No 03-04-2013B

AN ORDINANCE CHANGING Chapter 19 of the Orangeville Book of Municipal Codes

WHEREAS Orangeville Code does not currently specifically address the water tower as part of the public water system, to include a definition of “water tower”, and

WHEREAS over time, other organizations and businesses have received permission or paid rental fees to attach electronic equipment from the tower, and

WHEREAS the Village has sustained damage and rust stains from said attachments or during installation of said attachments,

BE IT ORDAINED By the Trustees of the Village of Orangeville, Stephenson County, Illinois that the following changes are made to Chapter 19, Village Water Codes:

1. Section 19-2 – GENERAL – TERMS AND DEFINITIONS is changed to add:

WATER TOWER. The term “water tower”, when used herein, shall mean the part of the public water supply that includes the storage tank, the supporting structure and appurtenances.

2. Article X is replaced and Sec 19-126 is added as follows:

ARTICLE X: WATER TOWER (WT)

Sec 19-126 WT - WATER TOWER

- A. Any entity renting, leasing or given Village Board approval to install equipment on the Village water tower shall abide by Village codes. Such entities may be required to show proof of bonding and insurance.
- B. The antenna or other installation must comply with FAA requirements. If new antennas are installed on top of the tank or appurtenances, FAA obstruction lighting may need to be installed or raised to meet FAA requirements. These requirements are the responsibilities of the owner of the equipment.
- C. Bolted or clamped components used on the exterior of the tank or appurtenances shall be painted, seal welded, or caulked to prevent corrosion and rust streaking. All clamps to be stainless steel or high grade galvanized and guaranteed not to rust or corrode.
- D. When electrical equipment is installed inside the support structure of single pedestal tanks, the effects of high humidity and condensation and equipment shall be adequately protected as in C above.

E. Access to equipment shall comply with Occupational Safety and Health Administration (OSHA) regulations. Wearing of harness and tie off is required of all personnel working on tower.

F. Antenna cables shall be supported every four feet in exposed locations. Any and all equipment shall not interfere with OSHA-defined access. Cables or equipment shall not be attached to ladders or obstruct manholes and platforms.

G. Any damage to the water tower by equipment will be the responsibility of the owner of said equipment, who will be required to make repairs. The Village of Orangeville is not responsible for any installed equipment.

Sec. 19-127 through Sec. 19-131 RESERVED.

3. The former ARTICLE X, PROHIBITED ACTS (PA) is renumbered as ARTICLE XI.

4. The former ARTICLE XI, PENALTIES is renumbered as ARTICLE XII

BOARD OF TRUSTEES	AYE	NAY	ABSENT
Edward Dotzel			
Alex Mills			
Kurt Schilling			
Caryl Buford			
Louis Piskur			
Michael Siedschlag			

Village Clerk
Joyce Flannery

Village President
Donald L. Hoyle